

Health Department, Haryana (Faridabad)

O/o Civil Surgeon, Faridabad


Hygiene Certificate

No. H.H.G./Fadl. 2025-26/72

Date 11.12.2025

Certified that the inspection of the .Asha Jyoti Vidyapeeth.....
..Sahubura, opposite sec-65, Malviya Bypass Road, Faridabad....
.....School has been carried out on Date 3.12.2025.....The
Hygienic condition was found
satisfactory/Unsatisfactory

The above Certificate is valid till 31.3.2026.... Date


Signature with Seal:
Dy. Civil Surgeon (School Health)
Faridabad

Memo No:- 1359

Date:- 10/09/2025

Certificate
No: TC-9082

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : FBD/02634/9/2025 / Private	Sample Details	Date & Time
Sender : Asha jyoti vidyapeeth	Collected By	Anil kumar
Location : , Sahupura opposite sev 65 main bypass road farid	Collection Date	03/09/2025 at 13:33
Sample Description : Drinking Water	Received at lab	08/09/2025 at 11:55
Latitude / Longitude : 76.433301 / 29.057720	Analysis Start Date	08/09/2025
	Analysis End Date	09/09/2025
	Sample Quantity	1 Litre

Test Result (As Per BIS 10500 :2012)					
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.29	1 NTU	5 NTU	APHA 24th edition ,2130 B:2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
4	Color	7	5 Hazen Units	15 Hazen Units	APHA 24 th EDITION- 2120 C:2023
5	Total Dissolved Solids @ 180°C ± 2°C	156	500 mg/l.	2000 mg/l.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	110	200 mg/l.	600 mg/l.	APHA 24th Edition -2340 C
7	Calcium as Ca	24.04	75 mg/l.	200 mg/l.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	12.15	30 mg/l.	100 mg/l.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	90	200 mg/l.	600 mg/l.	APHA 24th Edition -2320 B
10	Chloride as Cl	95.62	250 mg/l.	1000 mg/l.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So ₄	48	200 mg/l.	400 mg/l.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride as F	0.30	1.0 mg/l.	1.5 mg/l.	APHA 24th Edition 4500 F-D:
13	Iron as Fe	0.03	1.0 mg/l.	1.0 mg/l.	USEPA 45(126:43459):2023, APHA 24th EDITION 3500-Fe-B
14	Nitrate as NO ₃	4.86	45 mg/l.	45 mg/l.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	6.78	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

Vandana
VANDANA DESWAL, CHEMIST
DISTRICT WATER TESTING LABORATORY FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

Samita Reza



PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, FARIDABAD

Website :- <https://phedharyana.gov.in/>

Memo No:- 1365

Date:- 10/09/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FBD/02666/9/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	Anil kumar,8700614391
Sender:	Asha jyoti vidyapeeth	Collection Date	05/09/2025 at 12:45
Location :-	, Sahupura oppsite sec 65 main bypass road	Received at lab	08/09/2025 at 11:55
Latitude :-	77.345934	Tested at Lab	10/09/2025
Longitude :-	28.299714		

Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "POTABLE"



Vandana
VANDANA DESWAL,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

-----End of Report-----

Samita Reza